



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2019010307190242

NAME AND ADDRESS OF THE APPLICANT

ZHEJIANG GEYA ELECTRICAL CO.,LTD

Wenzhou Bridge Industrial Zone, Beibaixiang Town, Yueqing, Zhejiang, China

NAME AND ADDRESS OF THE MANUFACTURER

ZHEJIANG GEYA ELECTRICAL CO.,LTD

Wenzhou Bridge Industrial Zone, Beibaixiang Town, Yueqing, Zhejiang, China

NAME AND ADDRESS OF THE FACTORY

Zhejiang Huanyong Electric Co., Ltd.

Qiligang Road Liushi Town Yueqing City Zhejiang Province

PRODUCT NAME, MODEL AND SPECIFICATION

MOULDED CASE CIRCUIT-BREAKER

GYCM3-630L/3300、GYCM3-630L/4300、GYCM3-630M/3300、GYCM3-630M/4300; Ui: 1000V; Ue: AC400V; Uimp: 12kV; In: 400A、500A、630A; Over-current Release: Thermal Magnetic; Ics: L: 35kA、M: 50kA; Icu: L: 50kA、M: 65kA; Utilization Category: A; Poles: 3P、4P(With three protective poles, Switched neutral pole); Suitable for insulation

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.2-2008

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: May.29,2019

Valid until: Mar.20,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2019010307190243

NAME AND ADDRESS OF THE APPLICANT

ZHEJIANG GEYA ELECTRICAL CO.,LTD

Wenzhou Bridge Industrial Zone, Beibaixiang Town, Yueqing, Zhejiang, China

NAME AND ADDRESS OF THE MANUFACTURER

ZHEJIANG GEYA ELECTRICAL CO.,LTD

Wenzhou Bridge Industrial Zone, Beibaixiang Town, Yueqing, Zhejiang, China

NAME AND ADDRESS OF THE FACTORY

Zhejiang Huanyong Electric Co., Ltd.

Qiligang Road Liushi Town Yueqing City Zhejiang Province

PRODUCT NAME, MODEL AND SPECIFICATION

MOULDED CASE CIRCUIT-BREAKER

GYCM3-800/3300、GYCM3-800/4300; Ui: 1000V; Ue: AC400V; Uimp: 12kV; In: 630A、700A、800A;
Over-current Release: Thermal Magnetic; Ics: 65kA; Icu: 85kA; Utilization Category: A类; Poles: 3
P、4P(With three protective poles,Switched neutral pole); Suitable for insulation

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.2-2008

This is to certify that the above mentioned product(s) complies with the requirements of
implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: May.29,2019

Valid until: Mar.20,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by
issuing certification body until the expiry date.

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2019010307190241

NAME AND ADDRESS OF THE APPLICANT

ZHEJIANG GEYA ELECTRICAL CO.,LTD

Wenzhou Bridge Industrial Zone, Beibaixiang Town, Yueqing, Zhejiang, China

NAME AND ADDRESS OF THE MANUFACTURER

ZHEJIANG GEYA ELECTRICAL CO.,LTD

Wenzhou Bridge Industrial Zone, Beibaixiang Town, Yueqing, Zhejiang, China

NAME AND ADDRESS OF THE FACTORY

Zhejiang Huanyong Electric Co., Ltd.

Qiligang Road Liushi Town Yueqing City Zhejiang Province

PRODUCT NAME, MODEL AND SPECIFICATION

MOULDED CASE CIRCUIT-BREAKER

GYCM3-400L/3300、GYCM3-400L/4300、GYCM3-400M/3300、GYCM3-400M/4300; Ui: 1000V; Ue: AC400V; Uimp: 12kV; In: 225A、250A、315A、350A、400A; Over-current Release: Thermal Magnetic; Ics: L: 35kA、M: 50kA; Icu: L: 50kA、M: 65kA; Utilization Category: A; Poles: 3P、4P(With three protective poles,With one protective pole); Suitable for insulation

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.2-2008

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: May.29,2019

Valid until: Mar.20,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2019010307190237

NAME AND ADDRESS OF THE APPLICANT

ZHEJIANG GEYA ELECTRICAL CO.,LTD

Wenzhou Bridge Industrial Zone, Beibaixiang Town, Yueqing, Zhejiang, China

NAME AND ADDRESS OF THE MANUFACTURER

ZHEJIANG GEYA ELECTRICAL CO.,LTD

Wenzhou Bridge Industrial Zone, Beibaixiang Town, Yueqing, Zhejiang, China

NAME AND ADDRESS OF THE FACTORY

Zhejiang Huanyong Electric Co., Ltd.

Qiligang Road Liushi Town Yueqing City Zhejiang Province

PRODUCT NAME, MODEL AND SPECIFICATION

MOULDED CASE CIRCUIT-BREAKER

GYCM3-125L/3300、GYCM3-125L/4300、GYCM3-125M/3300、GYCM3-125M/4300; Ui: 1000V; Ue: AC400V; Uimp: 12kV; In: 16A、20A、25A、32A、40A、50A、63A、80A、100A、125A; Over-current Release: Thermal Magnetic; L: Ics: 22kA, Icu: 35kA; M: Ics: 35kA, Icu: 50kA; Utilization Category: A; Poles: 3P, 4P(With three protective poles,With one protective pole); Suitable for insulation

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.2-2008

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: May.29,2019

Valid until: Nov.15,2023

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2019010307190240

NAME AND ADDRESS OF THE APPLICANT

ZHEJIANG GEYA ELECTRICAL CO.,LTD

Wenzhou Bridge Industrial Zone, Beibaixiang Town, Yueqing, Zhejiang, China

NAME AND ADDRESS OF THE MANUFACTURER

ZHEJIANG GEYA ELECTRICAL CO.,LTD

Wenzhou Bridge Industrial Zone, Beibaixiang Town, Yueqing, Zhejiang, China

NAME AND ADDRESS OF THE FACTORY

Zhejiang Huanyong Electric Co., Ltd.

Qiligang Road Liushi Town Yueqing City Zhejiang Province

PRODUCT NAME, MODEL AND SPECIFICATION

MOULDED CASE CIRCUIT-BREAKER

GYCM3-250L/3300、GYCM3-250L/4300、GYCM3-250M/3300、GYCM3-250M/4300; Ue: AC400V; Ui: 100
0V; Uimp: 12kV; In: 100A、125A、160A、180A、200A、225A、250A; Over-current Release: Thermal
Magnetic; Ics: L: 22kA、M: 50kA; Icu: L: 35kA、M: 65kA; Utilization Category: A; Poles: 3P、
4P(With three protective poles,Switched neutral pole); Suitable for insulation

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.2-2008

This is to certify that the above mentioned product(s) complies with the requirements of
implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: May.29,2019

Valid until: Mar.20,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by
issuing certification body until the expiry date.

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE