

C E R T I F I C A T E



of Conformity
Low Voltage Directive 2014/35/EU

Registration No.: AN 50574858 0001

Report No.: CN22RUMC 002

Holder: Zhejiang GEYA Electrical co.,Ltd
Wenzhou Brige Industrial
Zone Beibaixiang Town
Yueqing
325603 Zhejiang
P.R. China

Product: Magnetic Contactor
(Electromechanical contactor for household and similar purposes)

Identification: Type Designation: GYHC-16 , GYHC-20 , GYHC-25
(GEYA)
Standards: EN 61095: 2009
Ratings :Ue=AC 250V(1P/2P),AC 400V (3P/4P),50/60Hz;
AC-7a:Ie=16/20/25A; Ui=500V; Ith=25A; Uimp=4,0kV;
Us=AC24/110/230V,DC12/24V; Ir=Iq=1kA(16/20A); Ir=Iq=3kA(25A)
Remark: Issued in conjunction with TÜV Rheinland report
CN22RUMC 002

This certificate of conformity is based on an evaluation of a sample of the above mentioned product. Technical Report and documentation are at the Licence Holder's disposal. This is to certify that the tested sample is in conformity with Annex I of Council Directive 2014/35/EU, referred to as the Low Voltage Directive. This certificate does not imply assessment of the series-production of the product and does not permit the use of a TÜV Rheinland mark of conformity. The holder of the certificate is authorized to use this certificate in connection with the EC declaration of conformity according to Annex IV of the Directive.

Certification Body

Date 06.03.2023

A blue ink signature of Wencai Zhang over a circular stamp. The stamp contains the text "TÜV Rheinland LGA Products GmbH" and "Zertifizierungsstelle".
Wencai Zhang

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

CE The CE marking may be used if all relevant and effective EC Directives are complied with. CE

Zhejiang GEYA Electrical co.,Ltd
Kitty Qian

Date : 07.03.2023
Our ref. : DY 01
Your ref.: K.Q

Wenzhou Brige Industrial
Zone Beibaixiang Town
Yueqing
325603 Zhejiang
P.R. China

Ref : AN Certificate of Conf. Low Voltage D.

Type of Equipment : Electromechanical contactor for household and similar purposes

Model Designation : See Certificate

Certificate No. : AN 50574858 0001

Report No. : CN22RUMC 002

Dear Kitty Qian,

We herewith confirm that a sample of the above mentioned technical equipment has been tested and was found to be in accordance with the relevant requirements.

Enclosed please find your Certificate of Conformity.

We appreciate your kind support and would like to offer our assistance and continuous services in the future.

With kind regards,

Certification Body



Wencai Zhang

CC: Zhejiang KEOSTI Electric Co., Ltd.

Enclosure

证书的详细资料请登陆www.certipedia.com查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询

C E R T I F I C A T E



of Conformity
Low Voltage Directive 2014/35/EU

Registration No.: AN 50574871 0001

Report No.: CN22WKES 002

Holder: Zhejiang GEYA Electrical co.,Ltd
Wenzhou Brige Industrial
Zone Beibaixiang Town
Yueqing
325603 Zhejiang
P.R. China

Product: Magnetic Contactor
(Electromechanical contactor for household and similar purposes)

Identification: Type Designation: GYHC-32 , GYHC-40 , GYHC-63
(GEYA)
Standards: EN 61095: 2009
Ratings: Ue=AC 250V(1P/2P), AC 400V (3P/4P), 50/60Hz;
AC-7a: Ie=32/40/63A; Ith=63A; Ui=500V; Uimp=4,0kV
Us=AC24/110/230V, DC12/24V; Ir=Iq=3kA
Remark: Issued in conjunction with TÜV Rheinland report

CN22WKES 002

This certificate of conformity is based on an evaluation of a sample of the above mentioned product. Technical Report and documentation are at the Licence Holder's disposal. This is to certify that the tested sample is in conformity with Annex I of Council Directive 2014/35/EU, referred to as the Low Voltage Directive. This certificate does not imply assessment of the series-production of the product and does not permit the use of a TÜV Rheinland mark of conformity. The holder of the certificate is authorized to use this certificate in connection with the EC declaration of conformity according to Annex IV of the Directive.

Certification Body

Date 07.03.2023


Wencai Zhang

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg



The CE marking may be used if all relevant and effective EC Directives are complied with.



Zhejiang GEYA Electrical co.,Ltd
Kitty Qian

Date : 07.03.2023
Our ref. : DY 01
Your ref.: K.Q

Wenzhou Brige Industrial
Zone Beibaixiang Town
Yueqing
325603 Zhejiang
P.R. China

Ref : AN Certificate of Conf. Low Voltage D.

Type of Equipment : Electromechanical contactor for household and similar purposes
Model Designation : See Certificate
Certificate No. : AN 50574871 0001
Report No. : CN22WKES 002

Dear Kitty Qian,

We herewith confirm that a sample of the above mentioned technical equipment has been tested and was found to be in accordance with the relevant requirements.

Enclosed please find your Certificate of Conformity.

We appreciate your kind support and would like to offer our assistance and continuous services in the future.

With kind regards,

Certification Body



Wencai Zhang

CC: Zhejiang KEOSTI Electric Co., Ltd.

Enclosure

证书的详细资料请登陆www.certipedia.com查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询