

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Timer Relay

Name and address of the applicant

Zhejiang GEYA Electrical Co., Ltd.
Wenzhou Brige Industrial Zone, Beibaixiang Town, Yueqing City,
Zhejiang Province, China 325603

Name and address of the manufacturer

Same as applicant

Name and address of the factory

Note: When more than one factory, please report on page 2

Same as applicant

Ratings and principal characteristics

Ue= 220/230/240V~, 50/60Hz
Ie= 20A(THC-20A), 30A(THC-30A), 16A (other models)
Ith= Ie, Cat. AC-15
Ui= 320V, Uimp= 4kV

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

THC-15A, THC-15B, THC-15F, TS-GE2, THC-810, THC-170,
THC-20A, THC-30A

Additional information (if necessary may also be reported on page 2)

-

A sample of the product was tested and found to be in conformity with

IEC 60947-5-1:2016

As shown in the Test Report Ref. No. which forms part of this Certificate

210902130SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Torshamnsgatan 43
Box 1103
SE-164 22 Kista, Sweden



Signature:



Leif Mattsson

Date: 10 December, 2021