

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Moulded Case Circuit-breaker

Name and address of the applicant

ZHEJIANG GEYA ELECTRICAL CO.,LTD
Wenzhou Bridge Industrial Zone, Beibaixiang Town, Yueqing,
Zhejiang, P.R.China

Name and address of the manufacturer

ZHEJIANG GEYA ELECTRICAL CO.,LTD
Wenzhou Bridge Industrial Zone, Beibaixiang Town, Yueqing,
Zhejiang, P.R.China

Name and address of the factory

Note: When more than one factory, please report on page 2

Zhejiang DongAn Electrical Appliance Co., Ltd.
No677,dongda Street Electric Industrial Zone, North-Baixiang Town,
Yueqing Zhejiang Province,P.R.China

Ratings and principal characteristics

Ui:1000V;Uimp:8kV;Ue:AC400V;In:16A,20A,25A,32A,40A,50A,63A,80A,100A,125A;
Ics:27kA;Icu:36kA;Over-current release type:thermal magnetic;Selectivity category:A; Number
of poles:3P;Suitable for isolation.

Trademark / Brand (if any)

GEYA

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

GYCM3-125/3300;

Additional information (if necessary may also be
reported on page 2)A sample of the product was tested and found
to be in conformity withIEC 60947-2:2016/AMD1:2019;IEC 60947-2:2016(5th Edition);IEC
60947-1:2007;IEC 60947-1:2007/AMD1:2010;IEC
60947-1:2007/AMD2:2014As shown in the Test Report Ref. No. which
forms part of this Certificate

03601-A-23CB0156-S


This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: <http://www.cqc.com.cn>

Date: Dec.29,2023

Signature:


Xie ZhaoXu